

10/01

DR, DRT

AIR TEMPERATURE SENSORS

Specification No. DR/DRT - 337-X-XXX*

The Invensys range of air temperature sensors are designed for use with Invensys controllers to provide temperature control of heating and air conditioning plant. For typical applications see relevant controller data sheets.

These room sensors are designed to be aesthetically pleasing and the neutral colours are sure to fit in with most types of room décor.

A Guard kit is available for use the adjustable DRT to prevent occupants from adjusting the set-point out of a pre-selected range. Alternatively the temperature scale can be replaced with a scale which reads '+' or '-' only.



* For the full specification number replace the 4Xs with the appropriate figures from the TYPE column in the table overleaf.

FEATURES

- · Aesthetically pleasing case designs
- · Small physical size
- Wide temperature sensing range
- Simple wiring connections
- Simple commissioning

Invensys is a trademark of Invensys plc and its subsidiaries and affiliates.





DS 10.104 - MN 620 DS 13.341 - BAS

Multi-Lingual Instructions MLI 1.001 - Installation Instructions

D3 2.110 - CAR
DS 2.120 - KMC
DS 2.201 - CZU
DS 2.541 - CSMC
DS 2.701 - MMC
DS 2.751 - MMC
DS 2.801 - IAC
DS 2.951 - IAC
DS 10.101 - MN 300
DS 10.102 - MN 440
DS 10.103 - MN 500

10/01 **SPECIFICATION**

Туре	Room or Duct	Adjustable Scale	Temp. Sensing Range	For use with controller or controller actuator types									
				CZT CXT CXR	csc	CMC CSMC	ммс	BAS	CZU	КМС	IAC	SVT	MN
		For further information see data sheets:		DS 2.105 DS 2.101 DS 2.110	DS 2.021	DS 2.041 DS 2.541	DS 2.701 DS 2.751	DS 13.341	DS 2.201	DS 2.120	DS 2.951 DS 2.801	DS 2.001	DS 10.101 DS 10.102 DS 10.103 DS 10.104
DR 3253	Room	None	-5/40°C	-	_	_	-	_	-	-	-	•	_
DRT 3451	Room	Exposed 10/35°C	-5/40°C	-	•	-	-	-	•	-	-	-	_
DRT 3452	Room	Concealed 10/35°C	-5/40°C	•*	-	-	-	-	•	-	-	-	-
DRT 3453	Room	None	-5/40°C	•*	•	•	•	•	•	•	•	-	•
DRT 3651	Room	Exposed 10/35°C	-5/40°C	•*	-	-	•	•	-	•	•	-	•
DRT 3652	Room	Exposed 10/35°C + LED	-5/40°C	-	-	-	-	-	-	-	•	-	•
*Not CVT													

*Not CXT	
Sensing element:	Negative temperature coefficient thermistor (0-10k ohm)
Wiring:	DRT 2, 3 or 4 wire low voltage dc. DR 2 wire low voltage dc.
Adjustment:	Where applicable, exposed adjustment.
Ambient temperature limits:	-40°C to +70°C
Characteristics:	See below:
Housing:	Tough fire resistant plastic case and back plate (IP 20)
Terminals:	Accept 1 x 1.5mm ²
Accessories:	837-1-203: Guard kit - Protects Detector against impact and tampering. 837-1-352: DRT +/- scale converter - Used to convert standard exposed adjustment room sensor scales to read + and – only. Consists of just the sensor front cover. Suitable for use with DRT 3451/3651 and RPW 4401/4425.

WIRING DIAGRAMS



DRT SENSOR CHARACTERISTICS						
Temperature °C	Resistance Ω	Temperature °C	Resistance Ω			
-5 0	8093 7661	60 65	2056 1792			
+5 10	7182 6667	70 75	1563 1364			
15 20	6126 5573	80 85	1193 1047			
25 30	5025	90 95	921 815			
35	3987	100	722			
40 45	3089					
50 55	2702					

Resistance $\boldsymbol{\Omega}$

TERMINAL DESIGNATIONS				
Sensor	Terminals			
DR 3253	А, В			
DRT 3451	A, B, C			
DRT 3452	A, B, C			
DRT 3651	A, B, C			
DRT 3652	A, B, C, D			
DRT 3453	B, C			

INSTALLATION OF THE DR & DRT ROOM SENSORS

- 1. Select a location for the sensor which is representative of the space to be controlled and where it will be readily affected by changes in the general space temperature level. The sensor location should also be reasonably clean and free from damp and condensation.
- 2. Remove the backplate by pushing in the fixing lugs on the top and bottom of the sensor with a small screwdriver or similar tool.
- 3. Thread the wires through the backplate and baffle card and fix it to the wall or conduit box with the arrow pointing upwards. The baffle card is used to ensure that there are not draughts from the cable entries to influence the sensed temperature.
- 4. Connect the wires to the sensor terminals on the sensor. See the data sheet for the controller the sensor is to be connected to for the terminal designations.
- 5. Refit the sensor housing to the backplate.



86

WIRING DIAGRAMS AND PRECAUTIONS

Refer to the Data Sheet relevant to the controller to which the sensor is to be connected. (See Table on Page 2). Maximum resistance is 15Ω per core.



Building Systems - UK Invensys Energy Solutions Farnham Road Slough Berkshire SL1 4UH United Kingdom

 Telephone
 +44 (0)1753 611000

 Facsimile
 +44 (0)1753 611001

 Web site
 www.ies.invensys.com

Cautions

- Do not apply any voltages until a qualified technician has checked the system and the commissioning procedures have been completed.
- If any equipment covers have to be removed during the installation of this equipment, ensure that they are refitted after installation to comply with UL and CE safety requirements.
- These sensors must only be used in conjunction with the appropriate Invensys Controllers shown on Page 2.
- Observe wiring precautions given on the data sheet for the controller that the sensor will be connected to.
 - Do not exceed the maximum ambient temperature.
 - Interference with parts under sealed covers invalidates guarantee.
 - Design and performance of Invensys equipment is subject to improvement and therefore liable to alteration without notice.
 - Information is given for guidance only and Invensys does not accept responsibility for the selection and installation of its products unless information has been given to the Company in writing relating to a specific application.
 - A periodic system and tuning check of the control system is recommended. Please contact you local Invensys service office for details.